



SEP. 1 1996

Certificate of Compliance

Certificate Number: LR 50822-1358


Revision: LR 50822-136S

Date Issued: August 27, 1996

Issued To: JMK INC.
15 Caldwell Dr.
Amherst, NH 03031
U.S.A.
Attention: Mr. James Kennedy


The products listed below are eligible to bear the CSA Mark.

**NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*



Issued By: E. Lee, C.E.T.
Toronto, ON Canada

Signature



CLASS

- 2221 02 - ELECTROMAGNETIC INTERFERENCE (EMI) FILTERS
- 2221 82 - ELECTROMAGNETIC INTERFERENCE (EMI) FILTERS - CERTIFIED TO U.S. STANDARDS

PRODUCTS

EMI filters, 125/250V, 50/60Hz, Model XX-0283-30, rated 30A; Model XX-0283-20, rated 20A; and Model XX-0283-10, rated 10A; Model XX-1151-20, rated 20A and Model XX-1151-30, rated 30A.

Note: XX may be A-Z to indicate line and load terminal configuration. Suffix letters B-Z may be added to indicate customer identification, external washers and AMP crimps to wires.

2
led
e 9/9/96

APPLICABLE REQUIREMENTS

- | | | | |
|-------------------|---------|---|--------------------------------------------|
| CSA Std C22.2 No. | 8-M1986 | - | Electromagnetic Interference (EMI Filters) |
| UL Std No. | 1283 | - | Electromagnetic Interference Filters |

* The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.